

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product	Heavy polychloroprene or other equivalent synthetic elastomer sheathed flexible cable
Name and address of the applicant	PEC SO CAVI SRL VIA SAN FERMO 2/B 46040 GAZOLDO DEGLI IPPOLITI MN Italy
Name and address of the manufacturer	PEC SO CAVI SRL VIA SAN FERMO 2/B 46040 GAZOLDO DEGLI IPPOLITI MN Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 PEC SO CAVI SRL VIA SAN FERMO 2/B 46040 GAZOLDO DEGLI IPPOLITI MN Italy
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	60245 IEC 66, 450/750 V
Trademark (if any)	PEC SO
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	60245 IEC 66 (H07RN-F)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 Tested cables: 5 x 1,5 mm ² , 1 x 50 mm ² (black colour) Certified cables: 1 x 1,5...50 mm ² , 2 x 1,5...25 mm ² , 3 x 1,5...16 mm ² , 4 x 1,5...16 mm ² , 5 x 1,5...10 mm ² (black colour) Additional tests according to EN 50525-2-21:2011
A sample of the product was tested and found to be in conformity with	IEC 60245-1:2003, IEC 60245-1:2003/AMD1:2007, IEC 60245-2:1994, IEC 60245-2:1994/AMD1:1997, IEC 60245-2:1994/AMD2:1997, IEC 60245-4:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	CN16-0007724-01, CN16-0007724-02

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.
Via Quintiliano 43, IT-I-20138 Milano, Italy

