

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Heavy polychloroprene or other equivalent synthetic elastomer sheathed flexible cable
Name and address of the applicant	PEC SO CAVI SRL VIA SAN FERMO 2/B 46040 GAZOLDO DEGLI IPPOLITI MN Italy
Name and address of the manufacturer	PEC SO CAVI SRL VIA SAN FERMO 2/B 46040 GAZOLDO DEGLI IPPOLITI MN Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 PEC SO CAVI SRL VIA SAN FERMO 2/B 46040 GAZOLDO DEGLI IPPOLITI MN Italy
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	60245 IEC 66, 450/750 V
Trademark (if any)	PEC SO
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	60245 IEC 66 (H07RN-F)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 Tested cables: 5 x 1 mm ² , 1 x 150 mm ² (black colour) Certified cables: 1 x 1,5...150 mm ² , 2 x 1...25 mm ² , 3 x 1...35 mm ² , 4 x 1...35 mm ² , 5 x 1...25 mm ² (black colour) Additional tests according to EN 50525-2-21:2011 This CB Test Certificate is a modification to CBTC Ref. No. IT-17920 dated 2017-05-15 and they must be read in conjunction. Modifications introduced: extension of cross-sectional area range.
A sample of the product was tested and found to be in conformity with	IEC 60245-1:2003, IEC 60245-1:2003/AMD1:2007, IEC 60245-2:1994, IEC 60245-2:1994/AMD1:1997, IEC 60245-2:1994/AMD2:1997, IEC 60245-4:2011
As shown in the Test Report Ref. No. which forms part of this Certificate	CN19-0036988-01; CN19-0036988-02

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.
Via Quintiliano 43, IT-I-20138 Milano, Italy